



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory -Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location:-SRI SAI EDUCATIONAL TRUST ORACLE PUBLIC SCHOOL Survey No.5 Opp :East Point Engineering College, Hirandahalli, Bengaluru-560049 Sample Particulars:R.O water				Reort date:04/04/2026	
				Report Number:0555	
				Reference:TRF	
				Sample code:0555	
				Date of sample collection:02/04/2026	
				Analysis start date:03/04/2026	
				Analysis completion date:03/04/2026	
				DISE Number:	
				Sample quantity:1 Liter	
Sl No	Test	Results	Acceptabl e limit Is 10500: 2012 RA:2018	Permissible Limit Is 10500: 2012 RA:2018	Protocol
Description: Colourless liquid					
1	Pff Value @25°C Temp	7.1	6.5-8.5	No relaxation	IS 3025(Part-11):2022
2	Specific Conductance,uS/cm@25°C Temp	100.0	-	-	IS 3025(Part-14):2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025(Part-5 & 6):2018
4	Colour,Hazen Units	<1.0	5	15	IS 3025(Part-4): 2021
5	Turbidity, NTU	0	1	5	IS 3025(Part-10): 2023
6	Total Dissolved Solids, mg/l@180°C	60	500	2000	IS 3025(Part-16):2023
7	Alkalinity as CaCO ₃ , mg/l	21.5	200	600	IS 3025(Part-23):2023
8	Total Hardness as CaCO ₃ ,mg/l	20	200	600	IS 3025(Part-21):2009
9	Calcium as Cl, mg/l	4.8	75	200	IS 3025(Part-40):1991
10	Magnesium as Mg, mg/l	1.9	30	100	IS 3025(Part-46):2023
11	Chloride as Cl, mg/l	15	250	1000	IS 3025(Part-32):1988
12	Sulphate as SO ₄ , mg/l	Nil	200	400	IS 3025(Part-24):2023
13	Fluoride as F, mg/l	0.1	1	1.5	APHA 24rd Edition
14	Nitrate as NO ₃ , mg/l	3	45	No relaxation	APHA 24rd Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025(Part-53):2024
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: <i>Megha K.S</i> Senior Analyst/Junior Analyst			Authorized Signatory: <i>Pavithra B.S</i> Technical Manager:Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

—END —



KARNATAKA GOVERNMENT

TALUK HEALTH OFFICE BANGALORE EAST TALUK K R PURAM BANGALORE

PHONE NO:-080 -- 25612400

E MAIL ID - thobangaloreeast2@gmail.com

REF: THO/NO:130/2026-27

DATE: 03-04-2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE..

It is certified that an inspection team headed by **Dr. B B RAGHUNATH I/C Taluk Health Officer** From Taluk Health Office, Bangalore East Taluk, Bangalore Urban District. (Name of Officer with designation 0) Health and family welfare Department inspected the Oracle public school hirandahalli. on 03-04-2026 and found that the school has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt .

The above valid for period of One Year

Signature: Dr. B B RAGHUNATH

Designation :TALUK HEALTH OFFICER

To,
THE Secretary
Oracle public school,
Virgonagar post
Bangalore – 560049.

TALUK HEALTH OFFICER
East Taluk, K.R. Puram
Bangalore Urban District.