



Office of the Chief Fire Officer, Bengaluru-East Zone,
Karnataka Fire & Emergency Services,
No.04, Commissariat Road, Bengaluru



NO.939/CFO/Bng-East/FSR/2025

Dated:15-04-2025

ANNEXURE -B

TO,
The Secretary,
M/s. Sri Sai Educational Trust (R)
Hirandahalli,
Bangalore -560 049.

Sir,

Sub: Issue of "Fire safety recommendation" to M/s. Oracle Public School,
Hirandahalli, Bangalore -56049"-reg
Ref:1) Your request letter dated: 11-03-2025.
2) Inspection report No.91/DFO/MFS-BNG/FSR?2025
dt:10/04/2025

<<<>>>

With reference to the subject above cited, the premises of M/s. Oracle Public School, Hirandahalli, Bangalore-560 049, was inspected by the District Fire Officer, Mahadevapura Fire Station, Bengaluru on 15-03-2025 with respect to Fire prevention, Fire fighting and Evacuation measures to be compiled in the premises and as Submitted the details as under.

Part -A. Details of the building/ premises:-

01	Name and Address of the Applicant.	:	The Secretary, M/s. Sri Sai Educational Trust(R) Hirandahalli, Bangalore-560 049
02	Name and Address of the premises	:	M/s. Sri Sai Educational Trust(R) Hirandahalli, Bangalore-560 049
03	Name and address of the Building Owner	:	The Secretary, M/s. Sri Sai Educational Trust(R) Hirandahalli, Bangalore-560 049
04	Number of buildings	:	1 Building.



05	Number of floors	:	Ground & 03 upper floors.
06	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	01 HM room, 01 staff room, 01 admin office, 01 reception, 10 class rooms, 01 store room, 01 secretary room & 03 wash rooms.
	1 st floor	:	13 class rooms, 01 computer lab & 02 wash rooms.
	2 nd floor	:	15 class rooms & 02 wash rooms.
	3 rd floor	:	09 class rooms, 01 biology lab, 01 chemistry lab, 01 physics lab & 02 wash rooms.
07	Height of the building	:	13.71mtrs.
08	Site area	:	2,033.09sq.mtrs.
09	<u>Built-up area of each floor:-</u>		
	Ground floor	:	728.73sq.mtrs.
	1 st floor	:	728.73sq.mtrs.
	2 nd floor	:	728.73sq.mtrs.
	3 rd floor	:	728.73sq.mtrs.
10.	Total built-up area	:	2,914.92sq.mtrs.
11.	<u>Surrounding properties:-</u>		
	North(Front)	:	Abutting Oracle Public School
	South(Rear)	:	Residential houses.
	West(Left)	:	Oracle Public School
	East(Right)	:	Residential houses.
12.	<u>Set-back area available around the building :-</u>		
	North(Front)	:	03.80mtrs.
	South(Rear)	:	01.50mtrs.
	West(Left)	:	01.00mtrs.
	East(Right)	:	01.50mtrs.

Part-B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-



13.	Fire fighting training	Not trained.	40% of the staffs/ Teachers Shall get trained in fire Prevention, fire fighting & Evacuation at R. A Mundkur fire & emergency Service Academy, Bannerghatta road, Bangalore - 560 029
-----	------------------------	--------------	---

Under the above circumstance, the Karnataka Fire & Emergency Services department has issued Fire Safety recommendation Certificate to M/s. Oracle Public School, Hirandahalli, Bangalore- 560 049. With subject to the condition for management To comply the requirements by providing additional fire fighting equipments and fire Precautionary measures as shown in column No.4 of part B as stipulated in NBC 2016 and then intimate to this office with 90 days positively without fail.

This Fire safety recommendation certificate is valid only for one year from the date of issue and should be renewed without fail.



Yours faithfully,

[Handwritten signature] 15/04/2025
Chief Fire Officer
Bengaluru East Zone
Bengaluru

Copy to the District Fire Officer,
Mahadevapura Fire Station, Bengaluru.

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)	
01.	Accessibility to the premises	The premise is accessible from 09.00mtrs wide Amara Jyothi School road located on the northern side.	Complied.	
02.	No. of entrances	One entrance and one exit have been provided.	Complied.	
03.	Width of entry / exit	01no entrance of 04.30mtrs width and 01no exit of 03.80mtrs width has been provided.	Complied.	
04.	Diesel generators.	Not provided.	Recommended to provide Suitable alternative power supply (Diesel generator) for emergency provisions of the building.	
05.	No. of staircases available	Nos. of staircases	: 02nos.	Complied.
		Width of staircases	: 1.50m. 1.00m.	
		Width of treads	: 30cms.	
		Height of risers	: 15cms.	
		Nos. of riser per flight	: 10Nos.	
		Height of handrails	: 1.00m.	
		Head room clearance	: 2.70m. 2.50m.	
06.	No. lifts and capacity.	Nos. of lifts	: Not provided.	Not applicable.
		Capacity of lifts	: provided.	
07.	Fire extinguisher	16nos ABC type extinguishers each of 6kgs capacity have been provided.	Recommended to provide 1no ABC type extinguisher of 4kgs capacity & 1 CO2 extinguisher of 4.50kgs capacity at every 100.00Sq.Mtrs of the school building and also	



FIRE SAFETY CERTIFICATE

NO.939/CF0/Bng-East/FSR/2025

Dated: 03-06-2025

Certified that the **Oracle Public School** (name of the building or premises) at **Hirandahalli, Bangalore** (address) comprised of 0 basement(s) and **Ground, First and Second** (upper floors) owned/occupied by **Oracle Public School** (Name of the institution) have compiled with the fire prevention and fire safety requirements in accordance in accordance with rule of State/UT Fire Service Rules ,and verified by the officers concerned of Fire Service on **10.04.2025** (date of inspection)in the presence of **Mr. Ganesh K** (name and addresses of the Manager/ Secretary or his representative) and that the building /premises is fit for occupancy upto classes **X (X / XII)** with effect from **15.03.2025** for a period of **one year** in accordance with rule and subject to compliance of specific conditions as appended:-

1.NA

2.NA

3.NA

4.NA

Issued on **15.03.2025**(date of issue) at **Mahadevapura** (place)by

* Strike out whichever is not applicable.



Signature with seal:

Name :**Mr.C.Basavanna**

Designation :

Name & Address of Department/Office:

To,

Oracle Public School,**Hirandahalli, Bengaluru**

(Name & Address of the institution)

Basavanna 03/06/2025
Chief Fire Officer
Bengaluru East Zone
Bengaluru

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....(reasons to be recorded).

(Name and designation of the authorized signatory)

*The filled-up certificate should be either in Hindi or English. If it is issued in Vernacular language, Translated notarized version in English be uploaded along with the original Vernacular certificate as a single pdf.